

## LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY GALVANIC CATHODIC PROTECTION SYSTEM EVALUATION

- This form may be utilized to evaluate underground storage tank (UST) cathodic protection (CP) systems in Louisiana.
- A site drawing depicting the UST system must be attached to the evaluation form.

I. UST OWNER				II. UST FACILITY	
NAME:		NAME:		AI#	
ADDRESS:		ADDRESS:			
CITY:	STATE:	CITY:	PARISH:		
III. REASON SURVEY WAS CONDUCTED					
<input type="checkbox"/> Routine - 3 year		<input type="checkbox"/> After Repair/Modification		<input type="checkbox"/> Within 6 months of Installation	
IV. CATHODIC PROTECTION TESTER'S EVALUATION					
<input type="checkbox"/> <b>PASS</b>		All protected structures at this facility pass the CP survey and the continuity survey indicates all protected structures are isolated			
<input type="checkbox"/> <b>FAIL</b>		One or more protected structures at this facility fail the CP survey			
<input type="checkbox"/> <b>INCONCLUSIVE</b>		Remote and local do not indicate the same test result on all protected structures (both pass or both fail), continuity survey indicates continuous or inconclusive results, or stray current is suspected to be affecting the structure			
CP TESTER'S SIGNATURE:			DATE OF CP SURVEY:		
CP TESTER			CP TESTER'S QUALIFICATIONS		
TESTER'S NAME:			NACE INTERNATIONAL CERTIFICATION NUMBER:		
COMPANY NAME:			OTHER:		
ADDRESS:			OTHER:		
V. CORROSION EXPERT'S EVALUATION					
<input type="checkbox"/> <b>PASS</b>		All protected structures at this facility have been judged to have adequate CP			
<input type="checkbox"/> <b>FAIL</b>		One or more protected structures at this facility fail the CP survey and it is judged that adequate CP has not been provided to the UST system			
CORROSION EXPERT'S NAME:			COMPANY NAME:		
NACE INTERNATIONAL CERTIFICATION:			NACE INTERNATIONAL CERTIFICATION NUMBER:		
CORROSION EXPERT'S SIGNATURE:				DATE:	
VI. CRITERIA APPLICABLE TO EVALUATION					
<input type="checkbox"/> <b>850 On</b>		Structure-to-soil potential more negative than -850 mV with respect to a Cu/CuSO <sub>4</sub> reference electrode with the protective current applied			
<input type="checkbox"/> <b>850 Instant Off</b>		Structure-to-soil potential more negative than -850 mV with respect to a Cu/CuSO <sub>4</sub> reference electrode with protective current temporarily interrupted (all anodes disconnected)			
<input type="checkbox"/> <b>100 mV Polarization</b>		Structure tested exhibits at least 100 mV of cathodic polarization			
VII. ACTION REQUIRED AS A RESULT OF THIS EVALUATION					
<input type="checkbox"/> <b>None</b>		Cathodic protection is adequate and no further action is necessary at this time			
<input type="checkbox"/> <b>Retest</b>		Cathodic protection may not be adequate – Retest during next 30 days to achieve passing results			
<input type="checkbox"/> <b>Repair &amp; Retest</b>		Cathodic protection is not adequate - Repair within 60 days of first fail and retest after repair			
The next "routine" test of the cathodic protection system must be conducted by no later than:					
UST-CP-01		Underground Storage Tank Division		Revision 0 – 10/15/2020	

**VIII. DESCRIPTION OF UST SYSTEM**

STATUS	PRODUCT	CAPACITY	TANK MATERIAL	INSTALL	PIPE MATERIAL	INSTALL	STP CONT. SUMP	MPD CONT. SUMP

**PIPING FLEX CONNECTORS**

LOCATION	TYPE of CORROSION PROTECTION		LOCATION	TYPE of CORROSION PROTECTION

**IX. DESCRIPTION OF CATHODIC PROTECTION SYSTEM REPAIRS AND/OR MODIFICATION**

- |   |   |  |
|---|---|--|
| <input type="checkbox"/> Anodes added to sti-P <sub>3</sub> <sup>®</sup> tank | <input type="checkbox"/> Anodes added to buried metallic pipe | <input type="checkbox"/> Anodes added to containment sumps |
| <input type="checkbox"/> Other (explain):                                     |   |  |

**COMMENTS:**

**DESCRIPTION OF REPAIRS NEEDED:**

**RECOMMENDATIONS FOR CONTINUED OPERATION:**

## X. CONTINUITY SURVEY

STRUCTURES TESTED		POINT-TO-POINT TEST	FIXED CELL-MOVING GROUND TEST			TEST RESULT
STRUCTURE "A"	STRUCTURE "B"	POINT-TO-POINT VOLTAGE DIFFERENCE (mV)	STRUCTURE "A" FIXED REMOTE VOLTAGE (mV)	STRUCTURE "B" FIXED REMOTE VOLTAGE (mV)	STRUCTURE "A" / "B" VOLTAGE DIFFERENCE(mv)	ISOLATED/ CONTINUOUS/ INCONCLUSIVE

REMARKS:

## XI. STRUCTURE-TO-SOIL POTENTIAL SURVEY

LOCATION OF REMOTE REFERENCE CELL 1 (R1):

NOTE: All measurements recorded in millivolts (mV) unless noted

LOCATION OF REMOTE REFERENCE CELL 2 (R2):

Ending voltage(s) recorded after (elapsed time):

STRUCTURE	STRUCTURE CONTACT POINT	LOCATION OF LOCAL REFERENCE CELL	LOCAL/ON VOLTAGE	REMOTE 1 VOLTAGE	REMOTE 2 VOLTAGE	INSTANT OFF VOLT	ENDING VOLTAGE	VOLTAGE SHIFT	PASS/FAIL/ INCONCLUSIVE

REMARKS: