

November 5, 2009

LDEQ ANSWERS TO PROPOSERS QUESTIONS
RFP No. 7225-09-03
“Abandoned Underground Storage Tank Site Investigation and Risk Evaluation”
U. P. Lachney Estate Property

LDEQ’s answers to the following questions are intended to provide information to potential proposers questions to RFP No. 7225-09-03.

Question 1: How deep are the wells on the property?

LDEQ’s answer: *The boring logs for MW-1 through MW-4 indicate that they were installed to a depth of 25’. The boring log for MW-5 did not have the depth labeled, but it was also installed to a depth of approximately 25’. The boring log for MW-6 indicates it was installed to a depth of 24.5’.*