

6.D Sector D. Asphalt Paving and Roofing Materials and Lubricant Manufacturers

6.D.1 Covered Storm Water Discharges

The requirements in Part 6.D apply to storm water discharges associated with industrial activity from Asphalt Paving and Roofing Materials and Lubricant Manufacturers as identified by the SIC Codes specified under Sector D in Table 1 of Part 1. You must comply with the Part 6 sector-specific requirements associated with your primary industrial activity and any co-located industrial activities as defined in Part 12. The sector-specific requirements apply to those areas of your facility where those sector-specific activities occur.

6.D.2 Industrial Activities Covered by Sector D

The SIC codes covered under Sector D are:

2951, 2952, 2992, and 2999

The types of activities that permittees under Sector D are primarily engaged in are:

- 6.D.2.1 manufacturing asphalt paving and roofing materials;
- 6.D.2.2 portable asphalt plant facilities; and
- 6.D.2.3 manufacturing lubricating oils and greases.

6.D.3 Limitations on Coverage

The following storm water discharges associated with industrial activity are not authorized by this sector:

- 6.D.3.1 discharges from petroleum refining facilities, including those that manufacture asphalt or asphalt products that are classified as SIC code 2911 (covered in Sector C);
- 6.D.3.2 discharges from oil recycling facilities (covered in Sector N); and
- 6.D.3.3 discharges associated with fats and oils rendering (covered in Sector U).

6.D.4 Monitoring and Reporting Requirements

Table D-2. SECTOR-SPECIFIC NUMERIC LIMITATIONS AND BENCHMARK MONITORING			
Sector of Permit Affected/Supplemental Requirements <i>Note: In addition to the following requirements, you must also comply with the requirements listed in Part 5 of the MSGP. If your SIC Code is not listed below then numeric limitations and benchmark monitoring do not apply except as otherwise noted below.</i>			
Subsector (You may be subject to requirements for more than one sector/subsector.)	Parameter	Benchmark Monitoring Concentration ¹	Numeric Limitation
Asphalt Paving and Roofing Materials (SIC 2951, 2952)	Total Suspended Solids (TSS)	100 mg/L	---
	Total Organic Carbon (TOC)	---	50 mg/L daily max. ²
	Oil & Grease	---	15 mg/L daily max. ²
Discharges from asphalt emulsion facilities	TSS	---	23 mg/L, daily max. ³
			15 mg/L 30-day avg. ³
	Oil and Grease	---	15 mg/L daily max. ³
			10 mg/L, 30-day avg. ³
	Total Organic Carbon (TOC)	---	50 mg/L daily max. ²
	pH	---	6.0 - 9.0 s.u. ³

¹ Monitor once/quarter for the year 2 and year 4 monitoring years (See Part 5.4.2 for possible year 4 monitoring waiver).

² The discharge from this permitted outfall shall not exceed a Daily Maximum of 50 mg/L Total Organic Carbon (TOC) or 15 mg/L Oil and Grease. **Unless required by Part 5.10 of this permit, analytical sampling and analysis of these parameters on a regular basis are not required.**

³ Monitor once per calendar year during each year of the term of the permit.