Site Name:	LDEQ Agency Interest (AI) #:
RAC Client:	
RAC Project Name:	
RAC Project Number:	

	MAINTENANCE SCHEDULE – LIQUID RING PUMP SYSTEM				
	WEEKLY I	MAINTENA	NCE TASKS		
	Task	₩ When Complete	Comments		
1.	Check oil level (if oil seal) and condition for the Liquid Ring Pump (LRP).				
2.	Check for water in oil sight gauge; drain off if necessary (if oil seal).				
3.	Observe scavenge line flow for the LRP.				
4.	Check the operation of the transfer pumps.				
5.	Note the backpressure of the Stripper blower.		\		
6.	Note backpressure of Air/Oil Demister filter. Should be (<) 4 PSIG. Replace as required (if oil seal).				
7.	Monitor the operation of the Stripper effluent pump and note the reading of the totalizing flow meter.				
8.	Drain solids from the bottom of AWS-1.				
9.	Check bag filter and carbon pressures. Change bags as necessary to maintain flow. Note the differential pressures from vessel to vessel.				
10.	Check levels on storage tanks. Empty, as necessary.				
11.	For systems with Liquid carbon, check backpressure and flow rate through totalizer. If flow rate is less than influent flow rate or 5 GPM, whichever is greater, back flush carbon vessel by switching the influent and effluent lines on the vessel. Allow 2-3 cycles and return hoses to original positions.				
12.	Check all return lines from AWS-3 (if oil seal) and carbon tanks. Make sure they free flow back to the AWS-1 tank.				
13.	Check air readings from each extraction line to calculate equivalent COC removal.				

Signature:_	 	
Date:		

	e Name:LDEQ Agency Interest (AI) #:			
C C	Client:			
C P	Project Name:			
AC P	Project Number:			
	MAINTENANCE SCHEDUL	E – LIQUII	D RING PUMP SYSTEM	
	MONTHLY MA	INTENAN	CE TASKS	
	Task	When Complete	Comments	
1.	Check transfer pumps and conductivity probes for signs of Mineral deposits and clean if necessary.			
2.	Grease the bearings on the Liquid Ring Pump (LRP) (every other month). Give each grease fitting 2 shots of grease.			
3.	Check and clean conductivity level probe rods in AWS-1.			
4.	Check and clean sight glass gauge for silt, iron, and calcium build-up. Replace sight glass if needed.			
5.	Inspect the OWS packing.			
6.	Check all hoses for deterioration.			
7.	Inspect the aeration tubes in the stripper.			
8.	Clean radiator of dust, dirt, leaves, etc (if oil seal).			
9.	Tighten nuts and bolts on liquid ring flanges and hose clamps.			
10.	Check all hoses for deterioration.			
11.	Inspect walls, motors, fans, components for any damages or corrosion.			
12.	Check the separation tanks AWS-1, AWS-2 and AWS-3 for solids or scaling.			
	ignature:			

ite N	ame:	LDE	Q Agency Interest (AI) #:	
AC C	lient:			
AC P	roject Name:			
MAINTENANCE SCHEDULE – LIQUID RING PUMP SYSTEM				
	Task	When Complete	Comments	
1.	Chemically descale transfer pump and conductivity probes and discharge check valve.			
2.	Clean Liquid Ring Pump (LRP) oil strainer for oil seal and wye strainer for water seal.			
3.	Check LRP system piping for leaks.			
4.	With power off, perform a wire pull test and tighten all electrical connections in the control panel.			
5.	With the power off, check all electrical connections at the motor junction boxes. Check the wires for corrosion.			
6.	Grease motors.			
7.	Test high level and high temperature sensors and alarms.			
8.	Test E stop button.			
9.	Calibrate vacuum transducer. With vacuum off, check and set the zero setting. With the vacuum running at a constant vacuum. Check and adjust the span screw, clockwise to adjust reading higher.			
10.	General structure inspection. Door, ceiling, wall panels for leaks or damage.			

Date:_____

e Name:LDEQ Agency Interest (AI) #:					
Client:					
C Pı	roject Name:				
C Project Number:					
MAINTENANCE SCHEDULE – POSITIVE DISPLACEMENT PUMP SYSTEM					
	WEEKLY MA	AINTENA	NCE TASKS		
	Task	When Complete	Comments		
1.	Check gear oil, temperature and condition of the PD vacuum pump, note any excessive temperature rise, oil consumption or vibration.				
2.	Check the operation of the transfer pumps.				
3.	Check the backpressure of the Stripper blower.				
4.	Monitor the operation of the stripper effluent pump and note the reading of the totalizing flow meter.				
5.	Drain solids from the bottom of AWS-1.				
5.	Check AWS-1inlet strainer. Strainer can be removed after the first month of operation.				
7.	Check, and drain/flush solids from the bottom of AWS-1tank.				
3.	Check levels on storage tanks. Empty as necessary.				
€.	Check bag filter and carbon pressures. Change bags as necessary to maintain flow. Note the differential pressures from vessel to vessel.				
10.	For systems with Liquid carbon, check backpressure and flow rate through totalizer. If flow rate is less than influent flow rate or 5 GPM, whichever is greater, back flush carbon vessel by switching the influent and effluent lines on the vessel. Allow 2-3 cycles and return				

lines on the vessel. Allow 2-3 cycles and return hoses to original positions.	
11. Check air readings from each extraction line to calculate equivalent COC removal.	
Signature: Date:	
Dutc.	

	AC Project Name:					
AC F	AC Project Number:					
	MAINTENANCE SCHEDULE – PO					
	MONTHLY M Task	When Complete	Comments			
1.	Check transfer pumps for signs of mineral deposits and clean if necessary.	_				
2.	Grease the bearings on the liquid ring pump (every other month). Give each grease fitting 2 shots of grease.					
3.	Check and clean conductivity level probe rods in AWS-1and sump.					
4.	Check and clean sight glass gauge for silt, iron, and calcium build-up. Replace sight glass if needed.					
5.	Inspect the OWS packing.					
6.	Inspect the aeration tubes in the Stripper.					
7.	Tighten nuts and bolts on flanges and hose clamps.					
8.	Check all hoses for deterioration.					
9.	any damage or corrosion.					
10	O. Check the separation tank for solids or scaling.					
	Signature:					

Naı	me:	LD	EQ Agency Interest (AI) #:					
AC Client:AC Project Name:AC Project Number:								
					MAINTENANCE SCHEDULE – POSITIVE DISPLACEMENT PUMP SYSTEM			
						QUARTERLY N		ANCE TASKS
	Task	When Complete	Comments					
1.	Chemically descale transfer pump and conductivity probes and discharge check valve.							
2.	Clean all wye-strainers.							
3.	Check PD blower vacuum system piping for leaks.							
4.	With power off, perform a wire pull test and tighten all electrical connections in the control panel.							
5.	With the power off, check all electrical connections at the motor junction boxes. Check the wires for corrosion.							
6.	Check gear oil level, top off as needed.							
7.	Refer to PO O&M manual for greasing and oil service. Transfer pump and air stripper blower motors have sealed bearings and do not require greasing.							
8.	Test high level and high temperature sensors and alarms.							
9.	Test the Stop button.							
10.	Calibrate vacuum transducer. With vacuum off, check and set the zero setting. With the vacuum running at a constant vacuum. Check and adjust the span screw, clockwise to adjust reading higher.							
11.	General structure inspection. Inspect door, ceiling, and wall panels for leaks or damage.							

Signature:		
Date:	 	

	MAINTENANCE S		
	Task	AINTENAN ✓ When Complete	Comments
1.	Check gear oil, temperature and condition of the vacuum pump, note any excessive temperature rise, oil consumption or vibration.		
2.	Check the operation of the transfer pumps.		
3.	Check AWS-1inlet strainer. Strainer can be removed after the first month of operation.		
4.	Check, and drain/flush solids from the bottom of AWS-1tank.		

RAC	Client:			
RAC	AC Project Name:			
RAC	Project Number:			
	MAINTENANCE SO	CHEDIILE	- SVE SYSTEM	
	MONTHLY M.			
	Task	✓ When Complete	Comments	
1.	Check transfer pumps and conductivity probes for signs of mineral deposits and clean if necessary.			
2.	Grease the bearings on the motor (every other month). Give each grease fitting 2 shots of grease.			
3.	Check and clean conductivity level probe rods in AWS-1.			
4.	Check and clean sight glass gauge for silt, iron, and calcium build-up.			
5.	Check vacuum gauges to ensure that max. Vacuum is not exceeded.			
6.	Inspect air filter on optional CFM gauge for moisture. Drain high vacuum switch.			
7.	Check motor amp draw. Check all switches for proper operation. Check all wiring for loose connections.			
8.	Tighten nuts and bolts on flanges and hose clamps.			
9.	Check moisture separator for pressure drop across filter/moisture demister(pressure drop should not exceed 6" H20 (0.44 in Hg) under normal operating conditions.)			
10.	Inspect walls, motors, fans, components for any damages or corrosion.			

Date:_

te Na	re Name:LDEQ Agency Interest (AI) #:		
AC CI	ient:		
AC Pr	oject Name:		
AC Pr	oject Number:		
	MAINTENANCE SO	CHEDULE	C - SVE SYSTEM
	QUARTERLY M	IAINTENA	NCE TASKS
	Task	✓ When Complete	Comments
1.	Chemically descale transfer pump and conductivity probes and discharge check valve optional.		
2.	Clean all wye-strainers.		
3.	Check vacuum system piping for leaks.		
4.	With power off, perform a wire pull test and tighten all electrical connections in the control panel.		
5.	With the power off, check all electrical connections at the motor junction boxes. Check the wires for corrosion.		
6.	Check gear oil level, top off as needed optional.		
7.	Refer to PO O&M manual for greasing and oil service. Transfer pump motors have sealed bearings and do not require greasing.		
8.	Test high level and high temperature sensors and alarms.		
9.	Test the Stop button.		
10.	Calibrate vacuum transducer. With vacuum off, check and set the zero setting. With the vacuum running at a constant vacuum. Check and adjust the span screw, clockwise to adjust reading higher.		
11.	General structure inspection. Inspect door, ceiling, and wall panels for leaks or damage.		

	11. General structure inspection. Inspect door, ceiling, and wall panels for leaks or damage.		
Signatu	re:	 	
Date:		 	

Site Name:	LDEQ Agency Interest (AI) #:
RAC Client:	
PAC Project Name:	
RAC Project Number:	

_	MAINTENANCE SCHEDULE – OZONE SPARGE SYSTEM				
	WEEKLY MAINTENANCE TASKS				
	Task	✓ When Complete	Comments		
1.	Check O2, O3, oxygen delivery pump, and air flow				
_	booster contactors.				
2.	Check the O3 production.				
3.	Check the O2 purity for proper production of O3.				
4.	Monitor the reactor pressure and O2 flow and compare against the manufacturers specifications.				
5.	Check O2 compressor inlet air filters. If needed clean or replace.				
6.	Check air flow booster compressor inlet air filters. If needed clean or replace.				
7.	Check water separator for proper function and check filters and O-ring. If needed clean or replace.				
8.	Check each ozone injection point for ozone leaks.				
9.	Inspect enclosure intake filters.				
10.	Test all auto drains.				
11.	Inspect HVAC and/or ventilation filters and louvers.				
12.	Test operation of heaters and exhaust fans.				
13.	Cycle through all ozone points, check, and record				
	pressure and flow at each point. If high breakthrough				
	pressures are present injection point may be plugged				
	of scaled over.				
	Check system lag times for proper settings.				
15.	Inspect integrity of hoses, fittings, piping, and valves				
16.	Inspect O2 moisture indicators. Blue indicates that				
	no moisture is present, pink or white indicates that				
	moisture is present. If moisture indicator is pink or				
	white disable ozone production and contact factory.				
17.	Check valve run times to insure system is running				
	properly on each point.				
18.	Check to see that the product type (O2, O3, etc) is				
	properly selected.				

		properly on each point.			
		Check to see that the product type (O2, O3, etc) is			
		properly selected.			
Si	Signature:				
D	Date:				

Si	ite Na	ame:	LDEQ Agency Interest (AI) #:		
R	RAC Client:				
R	AC Pı	oject Name:			
R	AC Pı	oject Number:			
		MAINTENANCE SCHEI	DULE – OZ	ZONE SPARGE SYSTEM	
		MONTHLY I	MAINTEN.	ANCE TASKS	
		Task	✓ When Complete	Comments	
	1.	Check pressure gauge to ensure that maximum pressure is not exceeded.			
	2.	Check motor amp draw. Check all switches for proper operation. Check all wiring for loose connections.			
	3.	Check for loose fittings and bolts.			
	4.	Check functionality of check valve.			
	5.	If applicable, check oil level and condition. Replace as recommended by manufacturer.			
	Signature: Date:				

ite Name:		LDEQ Agency Interest (AI) #:			
AC (Client:				
AC I	Project Name:				
AC I	Project Number:				
	MAINTENANCE CO	перш е	OZONE CDADCE CYCTEM		
MAINTENANCE SCHEDULE – OZONE SPARGE SYSTEM QUARTERLY MAINTENANCE TASKS					
	Task	✓ When Complete	Comments		
1.	Check Ozone Sparge system piping for leaks.				
2.	Inspect all plastic fitting in system for integrity.				
3.	With power off, perform a wire pull test and tighten all electrical connections in the control panel.				
4.	With the power off, check all electrical connections at the motor junction boxes. Check the wires for corrosion.				
5.	Check compressor oil level, top off as needed.				
6.	Refer to O&M manual for greasing and oil service.				
7.	Test high level and high temperature sensors and alarms.				
8.	Test the Stop button.				
9.	General structure inspection. Inspect door, ceiling, and wall panels for leaks or damage.				
Sig	nature:				

Note: Non-routine maintenance for the 6-month and 12-month service kits should be conducted as a System Repair (SR) not routine Operation & Maintenance (O&M).