

**Louisiana Department of Environmental Quality**  
**UST Containment Sump Integrity Verification Under High Tank Hold Water Level Conditions Form**

Facility Name: \_\_\_\_\_ Agency Interest Number: \_\_\_\_\_

Street Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Parish: \_\_\_\_\_

Testing Company Name: \_\_\_\_\_

Address: \_\_\_\_\_ City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Phone: \_\_\_\_\_

Tester Name, Printed: \_\_\_\_\_ Signature: \_\_\_\_\_

Date of Test: \_\_\_\_/\_\_\_\_/\_\_\_\_

			Sump Identifier/Number					
<b>Instructions:</b> Unless instructed otherwise, place your initials in the boxes on the right side of this form to indicate compliance with the checklist or steps for each sump.								
<b>Pre-Verification</b>	1	Determination that the tank hold water level is above the highest sump penetration and the sump sidewall seam, whichever is highest.						
	2	All liquid and debris has been removed from the containment sump.						
<b>Integrity Verification</b>	1	The interior of the containment sump has been dried.						
	2	A visual inspection of the entire containment sump was performed in order to determine if there are any cracks, holes, or compromised boots located in any portion of the sump as evidenced by water intrusion.						
<b>Indicate PASS or FAIL For Each Sump</b>								

Depth to tank hold water level: \_\_\_\_\_ Depth to highest penetration or sidewall seam: \_\_\_\_\_

Method used to verify tank hold water level:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_