

LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY IMPRESSED CURRENT CATHODIC PROTECTION SYSTEM EVALUATION

- This form may be utilized to evaluate underground storage tank (UST) impressed current CP systems in Louisiana.
- A site drawing depicting the UST system must be attached to the evaluation form.

I. UST OWNER				II. UST FACILITY	
NAME:			NAME:		AI #
ADDRESS:			ADDRESS:		
CITY:		STATE:	CITY:		PARISH:
III. REASON SURVEY WAS CONDUCTED					
<input type="checkbox"/> Routine - 3 year		<input type="checkbox"/> After Repair/Modification		<input type="checkbox"/> Within 6 months of Installation	
IV. CATHODIC PROTECTION TESTER'S EVALUATION					
<input type="checkbox"/> PASS		All protected structures at this facility pass the CP survey and continuity survey indicates all protected structures are continuous			
<input type="checkbox"/> FAIL		One or more protected structures at this facility fail the CP survey			
<input type="checkbox"/> INCONCLUSIVE		Continuity survey indicates isolated or inconclusive results, or stray current is suspected to be affecting the structure			
CP TESTER'S SIGNATURE:				DATE OF CP SURVEY:	
CP TESTER			CP TESTER'S QUALIFICATIONS		
TESTER'S NAME:			NACE INTERNATIONAL CERTIFICATION NUMBER:		
COMPANY NAME:			OTHER:		
ADDRESS:			OTHER:		
V. CORROSION EXPERT'S EVALUATION					
<input type="checkbox"/> PASS		All protected structures at this facility have been judged to have adequate CP			
<input type="checkbox"/> FAIL		One or more protected structures at this facility fail the CP survey and it is judged that adequate CP has not been provided to the UST system			
CORROSION EXPERT'S NAME:				COMPANY NAME:	
NACE INTERNATIONAL CERTIFICATION:				NACE INTERNATIONAL CERTIFICATION NUMBER:	
CORROSION EXPERT'S SIGNATURE:					DATE:
VI. CRITERIA APPLICABLE TO EVALUATION					
<input type="checkbox"/> 850 Instant Off		Structure-to-soil potential more negative than -850 mV with respect to a Cu/CuSO ₄ reference electrode with protective current temporarily interrupted (rectifier turned off)			
<input type="checkbox"/> 100 mV Polarization		Structure tested exhibits at least 100 mV of cathodic polarization			
VII. ACTION REQUIRED AS A RESULT OF THIS EVALUATION					
<input type="checkbox"/> Routine Monitoring		Cathodic protection is adequate – Monitor the rectifier every 60 days to ensure continued satisfactory operation			
<input type="checkbox"/> Retest		Cathodic protection may not be adequate – Retest during next 30 days to achieve passing results			
<input type="checkbox"/> Repair & Retest		Cathodic protection is not adequate - Repair within 60 days of first fail and retest after repair			
If the rectifier amperage falls below _____ amps during routine monitoring – Contact a qualified person to investigate					
The next "routine" test of the cathodic protection system must be conducted by no later than:					
UST-CP-02		Underground Storage Tank Division		Revision 0 – 10/15/2020	

VIII. DESCRIPTION OF UST SYSTEM

STATUS	PRODUCT	CAPACITY	TANK MATERIAL	INSTALL	PIPE MATERIAL	INSTALL	STP SUMP	MPD SUMP

PIPING FLEX CONNECTORS

LOCATION	TYPE of CORROSION PROTECTION	LOCATION	TYPE of CORROSION PROTECTION

IX. IMPRESSED CURRENT RECTIFIER DATA

RECTIFIER MANUFACTURER: _____ MODEL: _____ SERIAL #: _____

RATED DC OUTPUT: Volts Amps RECTIFIER SHUNT: mV = Amps SHUNT FACTOR = Amps/mV

AS FOUND	TAP SETTINGS OR RHEOSTAT %			DC OUTPUT										
	COARSE	FINE	RHEOSTAT	INDICATED VOLTS	INDICATED AMPS	MEASURED VOLTS	MEASURED AMPERAGE							
							(Shunt Voltage = mV)							
	POSITIVE AND NEGATIVE CIRCUIT MEASUREMENTS (Amps)												Anode Shunt Size = 0.01 Ω	
	CIRCUIT	1	2	3	4	5	6	7	8	9	10	11	12	TOTAL
	ANODE (+)													
STRUCTURE (-)														Amps

Mark this box if rectifier was not changed from the "As Found" settings

AS LEFT	TAP SETTINGS OR RHEOSTAT %			DC OUTPUT										
	COARSE	FINE	RHEOSTAT	INDICATED VOLTS	INDICATED AMPS	MEASURED VOLTS	MEASURED AMPERAGE							
							(Shunt Voltage = mV)							
	POSITIVE AND NEGATIVE CIRCUIT MEASUREMENTS (Amps)												Anode Shunt Size = 0.01 Ω	
	CIRCUIT	1	2	3	4	5	6	7	8	9	10	11	12	TOTAL
	ANODE (+)													
STRUCTURE (-)														Amps

X. DESCRIPTION OF CATHODIC PROTECTION SYSTEM REPAIRS AND/OR MODIFICATION

Anode(s) replaced Anode wire(s) replaced Negative wire repaired/replaced

Other (explain): _____

COMMENTS:

DESCRIPTION OF REPAIRS NEEDED:

RECOMMENDATIONS FOR CONTINUED OPERATION: Monitor and record the rectifier volts and amps with the appropriate form every 60 days

Take immediate action to have the system reevaluated by a qualified person if monitoring indicates the rectifier amperage falls below _____ amps

XI. CONTINUITY SURVEY

STRUCTURES TESTED		POINT-TO-POINT TEST	FIXED CELL-MOVING GROUND TEST			TEST RESULT
STRUCTURE "A"	STRUCTURE "B"	POINT-TO-POINT VOLTAGE DIFFERENCE (mV)	STRUCTURE "A" FIXED REMOTE VOLTAGE (mV)	STRUCTURE "B" FIXED REMOTE VOLTAGE (mV)	STRUCTURE "A" / "B" VOLTAGE DIFFERENCE(mV)	ISOLATED/ CONTINUOUS/ INCONCLUSIVE

REMARKS:

XII. STRUCTURE-TO-SOIL POTENTIAL SURVEY

NOTE: All measurements recorded in millivolts (mV) unless otherwise noted

STRUCTURE	STRUCTURE CONTACT POINT	LOCATION OF LOCAL REFERENCE CELL	ON VOLTAGE	INSTANT OFF VOLTAGE	STATIC VOLTAGE	VOLTAGE SHIFT	ELAPSED TIME	PASS/ FAIL

REMARKS: